



Computational Analysis of Heat Transfer in Nanofluid-Based Cooling Systems

¹Varkey Gopalkrishnan

¹Department of Computer Science and Engineering, Tonle Sap Institute of Engineering and Commerce Cambodia

¹varkey.gopalkrishnan@tsiec-kh.org

Peer Review Information

Submission: 05 March 2018

Revision: 15 April 2018

Acceptance: 25 May 2018

Keywords

Nanofluid, Heat transfer, Computational modeling, Microchannel cooling, Al₂O₃-water

Abstract

This methodology paper develops a reproducible computational framework for evaluating heat-transfer enhancement and hydraulic penalties in nanofluid-based cooling systems. A water-Al₂O₃ nanofluid is considered because of its extensive use in electronic and microchannel cooling studies. The model combines effective thermophysical-property relations with an axial finite-volume energy balance and a laminar pressure-drop formulation. Nanoparticle volume fractions of 0-3% and Reynolds numbers of 100-700 are evaluated in a rectangular mini/microchannel under a uniform wall heat flux of 100 kW/m². The computed indicators are average heat-transfer coefficient, Nusselt number, maximum wall temperature, pressure drop and pumping power. For Re = 500, increasing the nanoparticle fraction from 0 to 3% raises the predicted average heat-transfer coefficient from about 9.92 to 10.49 kW m⁻² K⁻¹, an enhancement of 5.67%, while the pressure-drop penalty is approximately 6.89%. The results demonstrate the expected trade-off between enhanced thermal conductivity and increased viscosity. The methodology is intended as a screening-level model that can support later high-fidelity CFD or experimental optimization of nanofluid cooling systems.

Introduction

Thermal management has become a limiting design issue in compact electronics, power devices, energy systems and high-heat-flux equipment. Conventional coolants such as water and ethylene glycol have relatively modest thermal conductivity, which restricts heat removal when heat-transfer area and coolant volume are constrained. Nanofluids were proposed to overcome part of this limitation by dispersing nanoscale solid particles in a base liquid so that the effective thermal transport properties can be modified without using millimeter-scale particles that readily settle or clog small channels. Early theoretical work emphasized both property enhancement and dispersion-related transport mechanisms (Xuan & Roetzel, 2000), while later application reviews

identified electronics and heat-exchanger cooling as especially promising areas (Saidur et al., 2011).

Computational analysis is valuable because nanofluid performance is not governed by thermal conductivity alone. Increasing particle concentration can improve heat transfer but also increases viscosity, pressure drop and pumping demand. The modeling choice itself is also important. Single-phase approaches treat the suspension as an equivalent homogeneous fluid, whereas two-phase approaches account for relative particle-fluid motion or concentration non-uniformity. Buongiorno (2006) showed that Brownian diffusion and thermophoresis are central slip mechanisms in many nanofluid flows, and Bianco et al. (2009) demonstrated that

single- and two-phase formulations can produce measurably different predictions in forced convection. Recent microchannel studies available by 2018 likewise stressed the need to consider both thermal and hydraulic behavior rather than reporting heat-transfer enhancement alone (Shi et al., 2018; Saeed & Kim, 2018).

The objective of the present paper is therefore to define, implement and demonstrate a compact methodology for computationally screening a water-Al₂O₃ coolant over practical laminar-flow conditions. The approach is deliberately transparent: all equations, assumptions, geometry, numerical steps and performance metrics are specified so that the analysis can be replicated or used as a pre-CFD design stage.

Literature Review

Foundational numerical studies established the feasibility of using nanofluids for convective heat-transfer enhancement. Khanafer et al. (2003) modeled buoyancy-driven heat transfer in a two-dimensional enclosure using a finite-volume formulation and showed that predictions are sensitive to the selected effective-property model. For forced convection, Maiga et al. (2004) numerically examined water-Al₂O₃ and ethylene-glycol-Al₂O₃ nanofluids in a uniformly heated tube and reported stronger heat transfer as particle concentration increased, accompanied by greater wall friction. Maiga et al. (2005) extended the forced-convection analysis to heated tubes and disks and again found substantial increases in heat-transfer coefficient with particle loading.

The physical interpretation and mathematical treatment of nanofluids continued to evolve. Buongiorno (2006) systematically examined particle-fluid slip mechanisms and developed a transport framework in which Brownian diffusion and thermophoresis are particularly relevant. Tiwari and Das (2007) used a finite-volume SIMPLE-based model to study mixed convection in a lid-driven cavity and showed that particle volume fraction significantly affects the heat-transfer response. Oztop and Abu-Nada (2008) subsequently analyzed natural convection in partially heated enclosures, confirming that particle type, volume fraction and flow-driving conditions can strongly modify mean Nusselt number.

Forced-convection modeling also highlighted the importance of representation fidelity. Bianco et al. (2009) compared homogeneous single-phase and discrete-particle approaches in an Al₂O₃-water tube flow and reported differences in predicted heat-transfer coefficients, particularly

when particle concentration and property variation were increased. Saidur et al. (2011) reviewed applications and challenges and concluded that nanofluids are attractive for thermal systems but remain limited by stability, viscosity, preparation cost and uncertainty in property correlations. Experimental work on Al₂O₃-water mini-channel heat sinks later confirmed measurable heat-transfer enhancement and thermal-resistance reduction, providing a practical basis for numerical cooling studies (Sohel et al., 2014).

By 2017-2018, research had become increasingly focused on compact cooling geometries and on the thermal-hydraulic trade-off. Arshad and Ali (2017) found that a TiO₂ nanofluid could increase heat transfer in a straight mini-channel heat sink, but pressure drop also required attention. Shi et al. (2018) proposed a numerical microchannel method that allowed nanoparticle concentration and local thermophysical properties to vary across computational cells; for 1% and 2% Al₂O₃ loadings they reported heat-transfer-coefficient increases of about 5.86% and 8.49%, respectively. Abdollahi et al. (2018) used three-dimensional simulation to examine Al₂O₃-water flow in interrupted microchannels and showed that channel geometry and a sufficient nanoparticle fraction jointly determine whether net enhancement is achieved. Saeed and Kim (2018) compared single- and two-phase numerical models with experiments in mini-channel heat sinks and found that the mixture model provided closer agreement. Finally, Mukherjee et al. (2018) emphasized that suspension stability is a prerequisite for reliable thermal performance, especially as concentration and operating temperature change.

The literature therefore supports a methodology that (i) evaluates effective properties consistently, (ii) resolves thermal development along the channel, (iii) reports both heat-transfer and pressure-drop metrics, and (iv) treats low-concentration predictions as screening estimates rather than universally transferable correlations. These points directly motivate the computational procedure adopted below.

Methodology

1. Computational domain and assumptions

A straight rectangular cooling channel is used as a representative element of a mini/microchannel heat sink. The channel length is 50 mm, width is 1.0 mm and height is 0.333 mm, giving a hydraulic diameter of approximately 0.50 mm.

Water at 300 K is the base fluid and spherical Al₂O₃ nanoparticles are added at volume fractions $\phi = 0, 0.01, 0.02$ and 0.03 . A uniform heat flux of 100 kW/m^2 is applied over the wetted channel wall. The analysis is steady, laminar and incompressible; radiation, phase

change, viscous dissipation and nanoparticle agglomeration are neglected. The suspension is treated as a homogeneous equivalent fluid for the screening calculation, consistent with common low-concentration single-phase modeling practice (Tiwari & Das, 2007; Bianco et al., 2009).




Figure 1. Step-by-step computational workflow used in the present methodology.

Input parameters

Table 1. Geometry and operating conditions for the computational analysis.

Parameter	Symbol	Value / range	Purpose
Channel length	L	50 mm	Thermal development length
Hydraulic diameter	Dh	0.50 mm	Characteristic dimension
Inlet temperature	T _{in}	300 K	Coolant boundary condition
Wall heat flux	q"	100 kW/m ²	Applied thermal load
Reynolds number	Re	100, 300, 500, 700	Flow-rate variable
Particle volume fraction	ϕ	0-3%	Nanofluid composition
Axial control volumes	N	200	Finite-volume resolution

2. Effective nanofluid properties

The density and heat capacity are calculated from phase-weighted mixture relations. Dynamic viscosity is estimated with the Brinkman form, and thermal conductivity is evaluated with the Maxwell spherical-particle expression. These compact relations are appropriate for a first-pass model and are widely used in earlier nanofluid computations, although more detailed studies may replace them with temperature- and concentration-dependent correlations (Xuan & Roetzel, 2000; Khanafer et al., 2003).

$$\rho_{nf} = (1 - \phi) \rho_f + \phi \rho_p$$

$$(\rho cp)_{nf} = (1 - \phi)(\rho cp)_f + \phi(\rho cp)_p$$

$$\mu_{nf} = \mu_f / (1 - \phi)^{2.5}$$

$$k_{nf} / k_f = [k_p + 2k_f - 2\phi(k_f - k_p)] / [k_p + 2k_f + \phi(k_f - k_p)]$$

3. Governing computational procedure

The channel is divided into 200 axial finite volumes. For each combination of Reynolds number and particle fraction, the mean velocity is obtained from $Re = \rho_{nf} U Dh / \mu_{nf}$. The mass flow rate is then $\dot{m} = \rho_{nf} U A$. Within

each axial cell, the bulk temperature is updated from a steady energy balance. This produces a monotonic coolant-temperature rise from inlet to outlet.

$$\dot{m} cp_{nf} (T_{b,i} - T_{b,i-1}) = q'' P \Delta x$$

Thermal development is represented with a laminar developing-flow Nusselt relation based on the local Graetz number. The relation approaches $Nu = 4.36$ as the flow becomes thermally developed. The local heat-transfer coefficient and wall temperature are then calculated from $h_i = Nu_i k_{nf} / Dh$ and $T_{w,i} = T_{b,i} + q'' / h_i$. This treatment preserves the axial variation in heat-transfer coefficient without requiring a full three-dimensional CFD mesh.

$$Gz_x = Re Pr Dh / x$$

$$Nu_x = 4.36 + [0.0668 Gz_x] / [1 + 0.04 Gz_x^{(2/3)}]$$

The hydraulic penalty is evaluated using the Darcy-Weisbach equation with the laminar friction factor $f = 64/Re$. Pressure drop and pumping power are computed as follows:

$$\Delta P = f (L/Dh) (\rho_{nf} U^2 / 2)$$

$$W_{pump} = \Delta P Q$$

4. Numerical sequence and convergence checks

1. Specify geometry, inlet temperature, wall heat flux, Reynolds number and nanoparticle fraction.
2. Calculate effective density, heat capacity, viscosity and thermal conductivity.
3. Determine velocity, mass flow rate and Prandtl number.
4. March through the 200 axial control volumes and update bulk and wall temperatures.
5. Compute local/average Nusselt number and heat-transfer coefficient.
6. Calculate pressure drop and pumping power, then compare against water at the same Reynolds number.
7. Repeat for all Reynolds numbers and particle fractions.

A grid check was performed by repeating representative cases with 100, 200 and 400 axial cells. Because the governing bulk-energy equation is first-order in the marching direction and the local heat-transfer coefficient varies smoothly, changes in maximum wall temperature between 200 and 400 cells were below 0.1%. Accordingly, 200 cells were retained. The base-fluid result also approaches the classical fully developed laminar limit downstream, providing an internal consistency

check. The method should be interpreted as a reduced-order screening tool; if particle migration, Brownian/thermophoretic transport or strongly nonuniform concentration is central to the application, a two-phase formulation such as those discussed by Buongiorno (2006) and Shi et al. (2018) is preferable.

Results

The computed results show two consistent effects. First, heat-transfer coefficient increases with Reynolds number because the developing thermal boundary layer is thinner at higher flow rates. Second, at a fixed Reynolds number, adding Al₂O₃ increases effective thermal conductivity and therefore raises h , while the viscosity increase produces a pressure-drop penalty. Figure 2 summarizes the average heat-transfer coefficient for all simulated cases.




Figure 2. Predicted average heat-transfer coefficient as a function of particle fraction and Reynolds number.

Table 2. Thermal-hydraulic results at Re = 500 from the present computational model.

ϕ (%)	h_{avg} (kW/m ² K)	h enhancement (%)	$T_{w,max}$ (K)	ΔP (kPa)	ΔP penalty (%)
0	9.92	0.00	325.32	4.69	0.00
1	10.11	1.83	325.10	4.79	2.11
2	10.29	3.72	324.87	4.90	4.40
3	10.49	5.67	324.64	5.02	6.89

At Re = 500, the average heat-transfer coefficient increases from 9.92 kW m⁻² K⁻¹ for water to 10.49 kW m⁻² K⁻¹ at ϕ = 3%. This corresponds to a 5.67% enhancement. The predicted maximum wall temperature decreases by about 0.68 K over the same concentration range, despite a small increase in outlet bulk temperature caused by changes in heat capacity and the mass flow needed to maintain constant Reynolds number. The thermal benefit is therefore visible most directly in the wall-to-bulk temperature difference and heat-transfer coefficient.

The pressure drops at Re = 500 increases from 4.69 kPa for water to 5.02 kPa at 3% nanoparticles, giving a 6.89% hydraulic penalty. Thus, the concentration producing the highest heat-transfer coefficient is not automatically the best system-level operating point. Similar thermal-hydraulic trade-offs were reported in earlier forced-convection calculations (Maiga et al., 2004; Maiga et al., 2005) and in mini/microchannel cooling studies by Arshad and Ali (2017), Abdollahi et al. (2018), Shi et al. (2018) and Saeed and Kim (2018).

The magnitude of enhancement in the present reduced-order model is intentionally

conservative because it does not add empirical Brownian-motion enhancement beyond the effective-property model. This is consistent with the role of the methodology as a baseline screening calculation. Published studies show that larger gains can occur when geometry-induced mixing, two-phase effects or concentration redistribution are captured, but such gains depend on particle size, stability, channel design and boundary conditions.

Conclusion and Discussion

This paper presented a step-by-step computational methodology for analyzing heat transfer in nanofluid-based cooling systems using a rectangular micro/mini-channel as the representative domain. The model combines effective Al₂O₃-water properties with an axial finite-volume energy balance, a developing-flow Nusselt formulation and a laminar Darcy-Weisbach pressure-drop model. The framework is simple enough for rapid design screening but still reports the two quantities required for realistic thermal management decisions: thermal enhancement and hydraulic cost. The calculations indicate that increasing Reynolds number is the dominant means of increasing the heat-transfer coefficient over the investigated range, while adding 1-3% Al₂O₃ provides an additional but more modest improvement. At Re = 500, 3% nanoparticles increased the average heat-transfer coefficient by approximately 5.67% and reduced the maximum wall temperature by about 0.68 K, but pressure drop rose by approximately 6.89%. Therefore, the optimum nanoparticle fraction should be selected from a combined thermal-hydraulic objective rather than from heat-transfer coefficient alone. These trends agree with the pre-2019 literature. Classical numerical studies consistently found that nanoparticle addition can improve convective heat transfer but may increase wall friction and pressure losses (Maiga et al., 2004; Tiwari & Das, 2007). More application-specific work reported similar trade-offs in compact heat sinks and showed that model fidelity and channel geometry can strongly influence predicted gains (Bianco et al., 2009; Abdollahi et al., 2018; Saeed & Kim, 2018). The stability issue reviewed by Mukherjee et al. (2018) is also important: a numerical model assumes a defined particle fraction, whereas agglomeration or sedimentation in a real system can change the local properties and invalidate the assumed homogeneous state. The main limitation is that the present computation uses a homogeneous single-phase property model and a reduced-order thermal-development correlation. It does not explicitly solve nanoparticle transport,

entrance-region momentum development, conjugate conduction through a solid heat sink, three-dimensional secondary flows or temperature-dependent properties. Consequently, the reported values should be used as screening results rather than as a substitute for validated CFD or experiment. A higher-fidelity continuation would solve the three-dimensional Navier-Stokes and energy equations with a mixture or Eulerian-Lagrangian treatment, conduct mesh-independence testing, and validate wall temperatures and pressure drops against measured data, as recommended by the modeling comparisons available up to 2018 (Shi et al., 2018; Saeed & Kim, 2018). Overall, the methodology demonstrates how a transparent computational model can be used to identify promising nanofluid concentrations before committing to expensive simulations or experiments. For low-concentration Al₂O₃-water cooling, the calculations support moderate heat-transfer enhancement with a comparable pressure-drop penalty; therefore, practical optimization should include pumping power, stability and allowable wall temperature simultaneously.

References

- Xuan, Y., & Roetzel, W. (2000). Conceptions for heat transfer correlation of nanofluids. *International Journal of Heat and Mass Transfer*, 43(19), 3701-3707. [https://doi.org/10.1016/S0017-9310\(99\)00369-5](https://doi.org/10.1016/S0017-9310(99)00369-5)
- Khanafer, K., Vafai, K., & Lightstone, M. (2003). Buoyancy-driven heat transfer enhancement in a two-dimensional enclosure utilizing nanofluids. *International Journal of Heat and Mass Transfer*, 46(19), 3639-3653. [https://doi.org/10.1016/S0017-9310\(03\)00156-X](https://doi.org/10.1016/S0017-9310(03)00156-X)
- Maiga, S. E. B., Nguyen, C. T., Galanis, N., & Roy, G. (2004). Heat transfer behaviours of nanofluids in a uniformly heated tube. *Superlattices and Microstructures*, 35(3-6), 543-557. <https://doi.org/10.1016/j.spmi.2003.09.012>
- Maiga, S. E. B., Palm, S. J., Nguyen, C. T., Roy, G., & Galanis, N. (2005). Heat transfer enhancement by using nanofluids in forced convection flows. *International Journal of Heat and Fluid Flow*, 26(4), 530-546. <https://doi.org/10.1016/j.ijheatfluidflow.2005.02.004>

- Buongiorno, J. (2006). Convective transport in nanofluids. *Journal of Heat Transfer*, 128(3), 240-250. <https://doi.org/10.1115/1.2150834>
- Tiwari, R. K., & Das, M. K. (2007). Heat transfer augmentation in a two-sided lid-driven differentially heated square cavity utilizing nanofluids. *International Journal of Heat and Mass Transfer*, 50(9-10), 2002-2018. <https://doi.org/10.1016/j.ijheatmasstransfer.2006.09.034>
- Oztop, H. F., & Abu-Nada, E. (2008). Numerical study of natural convection in partially heated rectangular enclosures filled with nanofluids. *International Journal of Heat and Fluid Flow*, 29(5), 1326-1336. <https://doi.org/10.1016/j.ijheatfluidflow.2008.04.009>
- Bianco, V., Chiacchio, F., Manca, O., & Nardini, S. (2009). Numerical investigation of nanofluids forced convection in circular tubes. *Applied Thermal Engineering*, 29(17-18), 3632-3642. <https://doi.org/10.1016/j.applthermaleng.2009.06.019>
- Saidur, R., Leong, K. Y., & Mohammed, H. A. (2011). A review on applications and challenges of nanofluids. *Renewable and Sustainable Energy Reviews*, 15(3), 1646-1668. <https://doi.org/10.1016/j.rser.2010.11.035>
- Sohel, M. R., Khaleduzzaman, S. S., Saidur, R., Hepbasli, A., Sabri, M. F. M., & Mahbubul, I. M. (2014). An experimental investigation of heat transfer enhancement of a minichannel heat sink using Al₂O₃-H₂O nanofluid. *International Journal of Heat and Mass Transfer*, 74, 164-172. <https://doi.org/10.1016/j.ijheatmasstransfer.2014.03.010>
- Arshad, W., & Ali, H. M. (2017). Experimental investigation of heat transfer and pressure drop in a straight minichannel heat sink using TiO₂ nanofluid. *International Journal of Heat and Mass Transfer*, 110, 248-256. <https://doi.org/10.1016/j.ijheatmasstransfer.2017.03.032>
- Shi, X., Li, S., Wei, Y., & Gao, J. (2018). Numerical investigation of laminar convective heat transfer and pressure drop of water-based Al₂O₃ nanofluids in a microchannel. *International Communications in Heat and Mass Transfer*, 90, 111-120. <https://doi.org/10.1016/j.icheatmasstransfer.2017.11.007>
- Abdollahi, A., Sharma, R. N., Mohammed, H. A., & Vatani, A. (2018). Heat transfer and flow analysis of Al₂O₃-water nanofluids in interrupted microchannel heat sink with ellipse and diamond ribs in the transverse microchambers. *Heat Transfer Engineering*, 39(16), 1461-1469. <https://doi.org/10.1080/01457632.2017.1379344>
- Saeed, M., & Kim, M. H. (2018). Heat transfer enhancement using nanofluids (Al₂O₃-H₂O) in mini-channel heatsinks. *International Journal of Heat and Mass Transfer*, 120, 671-682. <https://doi.org/10.1016/j.ijheatmasstransfer.2017.12.075>
- Mukherjee, S., Mishra, P. C., & Chaudhuri, P. (2018). Stability of heat transfer nanofluids - A review. *ChemBioEng Reviews*, 5(5), 312-333. <https://doi.org/10.1002/cben.201800008>