



Optimization of Power Distribution Losses Using Intelligent Control Techniques

Ornella Ghaznavi

Department of Electrical and Computer Engineering, Hanmir Advanced Engineering College, South Korea
ornella.ghaznavi@haec-kr.edu

Peer Review Information

Submission: 05 Jan 2019
Revision: 08 Feb 2019
Acceptance: 11 March 2019

Keywords

Distribution Loss
Minimization, Intelligent
Control, Network
Reconfiguration, Particle
Swarm Optimization,
Reactive Power
Compensation

Abstract

Electrical distribution networks experience substantial technical losses because of conductor resistance, reactive-power circulation, non-optimal feeder topology, and uneven loading. This paper develops a compact methodology for optimizing distribution losses through intelligent control techniques. The proposed framework integrates radial distribution load-flow analysis with network reconfiguration and reactive-power compensation, while intelligent optimizers search for feasible switch states and capacitor locations/sizes. Genetic algorithm (GA), particle swarm optimization (PSO), fuzzy multi-objective control, harmony search, ant-colony-based search, and hybrid schemes are treated as candidate controllers. The principal objective is the minimization of total real power loss subject to bus-voltage, branch-current, radiality, and load-supply constraints. The IEEE 33-bus radial distribution system is adopted as the principal benchmark because it is widely used for loss-minimization studies. A literature-aligned validation shows that simultaneous intelligent reconfiguration and capacitor placement can reduce the benchmark loss from 202.68 kW to approximately 93.06 kW, corresponding to about 54.08% reduction, while also improving the voltage profile. The methodology emphasizes repeatable power-flow evaluation, constraint handling, convergence testing, and fair algorithm comparison. The study concludes that hybrid intelligent control is more effective than isolated corrective actions because it jointly controls network topology and reactive-power support.

Introduction

Distribution systems are normally operated radially even though sectionalizing and tie switches provide alternative paths for service restoration and operational control. Because feeders have relatively high resistance-to-reactance ratios, a significant part of the supplied electrical energy may be dissipated as I^2R loss. Loss minimization therefore requires more than conventional dispatch: it requires coordinated control of feeder topology, reactive power, and operating constraints. Early feeder-reconfiguration methods established that changing switch status can reduce current

magnitudes and redistribute load without installing new conductors [1], [2]. Baran and Wu also formulated radial distribution optimization in a way that later became a standard basis for the 33-bus benchmark [2].

The search space becomes combinatorial because each switching action changes network topology and must preserve radiality and service continuity. Nara et al. demonstrated that genetic algorithms can encode feasible distribution configurations and solve loss-minimum reconfiguration as a mixed-integer optimization problem [3]. Reactive-power compensation provides a complementary control mechanism.

Classical capacitor-allocation research showed that correct capacitor location and size reduce feeder current, energy loss, and voltage drop [4], [5]. Consequently, modern loss optimization increasingly combines topology control with capacitor switching or distributed resource control.

Intelligent and metaheuristic methods are attractive because they can handle discrete variables, nonlinear load-flow equations, and multiple operational constraints without requiring differentiable objective functions. Fuzzy multi-objective methods can combine loss, voltage, branch-current and switching objectives [6], [8], while ant colony, harmony search, PSO and enhanced GA methods provide global or near-global exploration of the reconfiguration space [7], [9]-[13]. More recent pre-2019 studies extended intelligent optimization to capacitor placement and sizing under practical constraints [14], [15]. The objective of this paper is therefore to present a reproducible step-by-step methodology for comparing such intelligent control techniques and for constructing a hybrid strategy that minimizes distribution losses while maintaining acceptable network performance.

Literature Review

Research on distribution loss reduction can be grouped into three closely related streams: feeder reconfiguration, reactive-power compensation, and hybrid intelligent optimization. Civanlar et al. introduced a switching-based reconfiguration rule for reducing feeder losses [1], and Baran and Wu formalized network reconfiguration for both loss reduction and load balancing [2]. Nara et al. later applied a GA so that switch combinations could

be optimized rather than selected only by deterministic rules [3].

For capacitor control, Sundhararajan and Pahwa used a GA to select capacitors for radial systems [4], whereas Huang et al. used Tabu Search to solve the discrete capacitor-placement problem [5]. Huang's enhanced GA-fuzzy approach and Das's fuzzy multi-objective method showed that distribution optimization should also consider voltage deviation, branch-current loading, and switching effort instead of optimizing real-power loss alone [6], [8]. Su et al. applied ant colony search to reconfiguration [7], and Chang subsequently showed that reconfiguration and capacitor placement can be solved in a coordinated manner with ant-colony intelligence [9].

Swarm and music-inspired algorithms further broadened the solution space. Eajal and El-Hawary applied PSO to capacitor placement and sizing in unbalanced distribution networks with harmonic constraints [10]. Srinivasa Rao et al. demonstrated that harmony search can efficiently solve large-scale radial reconfiguration [11]. Sedighizadeh et al. used improved binary PSO to combine reconfiguration and capacitor placement and reported strong loss reduction on the IEEE 33-bus system [12]. Duan et al. improved GA operators to preserve radiality while addressing loss and reliability simultaneously [13]. Ali et al. used an improved harmony algorithm for capacitor allocation [14], while Tamilselvan et al. applied flower-pollination optimization to capacitor placement and reported competitive loss and voltage results [15]. These studies motivate a unified framework in which intelligent control is evaluated under identical power-flow and constraint conditions.

Table 1. Representative intelligent-control methods used for distribution loss reduction

Reference	Control/optimizer	Decision variables	Main contribution
[3] Nara et al. (1992)	GA	Switch states	Loss-minimum feeder reconfiguration
[6] Huang (2002)	Enhanced GA + fuzzy	Switch states	Multi-objective loss/voltage/current control
[7] Su et al. (2005)	Ant colony search	Switch states	Near-optimal feeder reconfiguration
[8] Das (2006)	Fuzzy multi-objective	Switch states	Balances loss, voltage and current limits
[11] Rao et al. (2011)	Harmony search	Switch states	Large-scale radial reconfiguration
[12] Sedighizadeh et al. (2014)	Improved binary PSO	Switch + capacitor states	Simultaneous topology and reactive control
[13] Duan et al. (2015)	Enhanced GA	Switch states	Loss reduction with reliability improvement
[15] Tamilselvan et al. (2018)	Flower pollination	Capacitor sites/sizes	Loss/cost minimization and voltage improvement

Methodology

The proposed methodology uses the IEEE 33-bus radial distribution system as the primary test network and applies the same load-flow model and constraints to every intelligent controller. This prevents a misleading comparison caused by different power-flow assumptions. The baseline case is evaluated first; optimization is then performed for feeder reconfiguration, capacitor placement, and a coordinated hybrid case. The method is organized into six implementation steps.

Step 1: Network Modeling and Baseline Load Flow

Bus, branch, resistance, reactance, active-load and reactive-load data are loaded into a radial network model. The source bus voltage is fixed at 1.0 p.u. and all loads are treated as constant PQ loads for the benchmark test. A backward/forward sweep or DistFlow-type method is used because it is robust for radial feeders with relatively high R/X ratios [2]. The baseline real-power loss is computed from the sum of branch copper losses: $P_{loss} = \sum I_k^2 R_k$. Bus voltages and branch currents are stored so that the optimizer can later compare every candidate configuration against the same reference case.

Step 2: Objective Function

The primary objective is minimum real-power loss. To keep the solution operationally acceptable, penalty terms are added for voltage violation, branch-current violation, loss of radiality, and disconnected load. A normalized

form is $F = w_1(P_{loss}/P_{base}) + w_2V_{pen} + w_3I_{pen} + w_4R_{pen} + w_5N_{sw}$, where N_{sw} is an optional switching term. For a pure loss study, w_1 is dominant; for multi-objective operation, fuzzy membership functions can replace fixed weights as proposed in earlier fuzzy reconfiguration studies [6], [8].

Step 3: Intelligent Control Variables

The controller encodes normally open and normally closed switch states as binary decision variables. For coordinated compensation, additional variables identify candidate capacitor buses and discrete capacitor ratings. GA uses chromosomes and crossover/mutation; binary PSO updates particle states from individual and global best solutions; harmony search generates candidate switch combinations from harmony memory; and fuzzy control ranks solutions using membership-based satisfaction. The same feasibility test is applied irrespective of optimizer.

Step 4: Constraint Handling and Radiality Check
Every candidate is rejected or penalized unless (i) all load buses remain energized, (ii) the topology remains radial, (iii) bus voltages remain within 0.95-1.05 p.u. unless another utility limit is specified, and (iv) branch currents remain below thermal limits. Graph connectivity and loop checks are performed before running the load flow; this avoids unnecessary computation for infeasible candidates. Enhanced GA and binary-PSO studies show that explicit radiality preservation substantially improves search efficiency [12], [13].




Figure 1. Step-by-step intelligent-control workflow for distribution loss optimization.

Step 5: Optimization and Convergence

A population of feasible solutions is initialized. Each candidate is decoded, checked for radiality, solved by load flow, and assigned an objective value. The intelligent optimizer then generates the next candidate population. The process stops when the maximum iteration count is reached or when the best objective value changes by less than a predefined tolerance for several consecutive iterations. For fair comparison, all

algorithms use the same number of objective-function evaluations and are executed repeatedly because stochastic algorithms can return slightly different solutions.

Step 6: Performance Evaluation

The final solution is assessed using percentage real-power-loss reduction, minimum bus voltage, voltage-deviation index, number of switching operations, convergence iterations, and computation time. The most useful controller is

not necessarily the one with the smallest single-run loss; it should also show reliable convergence and practical switching effort. A hybrid topology-plus-capacitor strategy is selected when it

provides a meaningful additional loss reduction without violating voltage, current, or switching constraints.

Table 2. Recommended benchmark settings for reproducible comparison

Parameter	Recommended setting	Purpose
Test system	IEEE 33-bus radial feeder	Common loss-minimization benchmark
Source voltage	1.0 p.u.	Uniform reference condition
Voltage limits	0.95-1.05 p.u.	Operational constraint
Load model	Constant PQ	Standard benchmark assumption
Population size	30-50 candidates	Balances search diversity and cost
Maximum iterations	100-200	Allows convergence comparison
Independent runs	20-30	Measures stochastic repeatability
Primary metric	Real power loss (kW)	Objective comparison

Results

The proposed methodology can be validated against published IEEE 33-bus benchmark behavior. Sedighizadeh et al. reported an initial loss of 202.68 kW and a coordinated reconfiguration-plus-capacitor result of 93.061 kW using improved binary PSO, equivalent to a 54.08% loss reduction [12]. This benchmark is

useful because it tests both discrete network switching and discrete reactive compensation under voltage, current, and radiality constraints. The result also supports the central methodological hypothesis: simultaneous intelligent control can outperform the sequential treatment of the two corrective actions.




Figure 2. Literature-aligned IEEE 33-bus benchmark loss before and after coordinated intelligent control [12].

Table 3. Expected comparative performance pattern under the proposed methodology

Case	Controller	Loss behavior	Voltage effect	Interpretation
Base	No optimization	202.68 kW [12]	Lowest profile	Reference condition
A	Reconfiguration only	Moderate reduction	Improved	Redistributes feeder currents
B	Capacitors only	Moderate reduction	Improved	Reduces reactive current
C	GA / HS / ACO reconfiguration	High reduction	Improved	Global search of switch states
D	Hybrid binary PSO	93.061 kW [12]	Best overall improvement	Coordinates topology and compensation

Earlier studies provide the qualitative comparison needed to interpret these results. Ant-colony reconfiguration can obtain near-optimal switch states [7], harmony search provides competitive large-system solutions [11], and enhanced GA improves feasibility and convergence by respecting radial topology [13].

Capacitor-oriented methods such as PSO, improved harmony search, and flower-pollination optimization improve voltage while reducing loss and compensation cost [10], [14], [15]. Therefore, the expected ranking is that a coordinated hybrid controller yields the strongest loss reduction, followed by intelligent

reconfiguration or optimized compensation alone. The exact ranking among GA, PSO, harmony search and ant colony methods depends on parameter tuning, stopping criteria, and the number of independent runs.

For a new experimental implementation, Table 3 should be populated with actual MATLAB, ETAP, OpenDSS, or DIgSILENT simulation outputs produced by the six-step procedure. Mean loss, standard deviation, best loss, minimum voltage and execution time should be reported across repeated runs rather than relying on a single stochastic result. This makes the methodology suitable for a defensible comparative paper rather than an algorithm demonstration only.

Conclusion and Discussion

This paper presented a methodology for optimizing power-distribution losses through intelligent control. The method combines radial load flow, feeder reconfiguration, reactive-power compensation, constraint checking, and a common benchmarking protocol. Classical reconfiguration research established that switch-state control can reduce I^2R loss [1]-[3], while capacitor optimization reduces reactive current and improves voltage [4], [5], [10], [14], [15]. Fuzzy, GA, ant-colony, harmony-search and binary-PSO studies show that intelligent optimization is particularly suitable for the mixed discrete and nonlinear nature of the problem [6]-[13]. The key methodological contribution is coordination. Instead of treating topology and reactive support as independent corrections, the proposed framework permits the optimizer to select them jointly. The published IEEE 33-bus benchmark demonstrates the potential benefit: improved binary PSO with simultaneous reconfiguration and capacitor placement reduced loss from 202.68 kW to 93.061 kW, or about 54.08% [12]. The improvement is physically reasonable because topology control changes the paths through which current flows, whereas capacitors reduce the reactive component of that current. Their combined action therefore attacks two major causes of feeder loss. For practical deployment, several limitations must be considered. Frequent switching can shorten equipment life; load demand varies with time; capacitor steps are discrete; and communication or measurement errors can alter the control decision. Future work should therefore extend the methodology to time-varying load profiles, renewable distributed generation, reliability indices, switching cost, and online state estimation. Nevertheless, for a comparative methodology study, the proposed six-step framework provides a clear, reproducible and technically grounded basis for evaluating

intelligent loss-minimization techniques. Algorithm selection should also be based on repeatability and implementation burden. GA offers intuitive binary encoding but may require careful crossover and mutation design to preserve radiality. PSO typically uses fewer structural operators and can converge rapidly, although its binary form must be designed to avoid excessive randomness. Harmony search and ant-colony methods are attractive for switch-combination problems because candidate solutions are naturally assembled from discrete states. Fuzzy logic is especially useful when operators wish to trade a small increase in loss against better voltage profile or fewer switching actions. Therefore, no single optimizer should be declared universally superior without using identical constraints, stopping rules, and computational budgets. A robust implementation should include sensitivity analysis. Population size, inertia or mutation parameters, penalty coefficients and voltage limits should be varied over reasonable ranges, and the stability of the best configuration should be recorded. If the same switch and capacitor pattern repeatedly appears under small parameter changes, the solution is more credible for engineering use. This robustness test, together with repeated stochastic runs and a common load-flow solver, strengthens the validity of any performance claim and is recommended before the method is applied to a practical distribution feeder.

References

- Civanlar, S., Grainger, J. J., Yin, H., & Lee, S. S. H. (1988). Distribution feeder reconfiguration for loss reduction. *IEEE Transactions on Power Delivery*, 3(3), 1217-1223. <https://doi.org/10.1109/61.193906>
- Baran, M. E., & Wu, F. F. (1989). Network reconfiguration in distribution systems for loss reduction and load balancing. *IEEE Transactions on Power Delivery*, 4(2), 1401-1407. <https://doi.org/10.1109/61.25627>
- Nara, K., Shiose, A., Kitagawa, M., & Ishihara, T. (1992). Implementation of genetic algorithm for distribution systems loss minimum re-configuration. *IEEE Transactions on Power Systems*, 7(3), 1044-1051. <https://doi.org/10.1109/59.207317>
- Sundhararajan, S., & Pahwa, A. (1994). Optimal selection of capacitors for radial distribution systems using a genetic algorithm. *IEEE Transactions on Power Systems*, 9(3), 1499-1507. <https://doi.org/10.1109/59.336111>

- Huang, Y.-C., Yang, H.-T., & Huang, C.-L. (1996). Solving the capacitor placement problem in a radial distribution system using tabu search approach. *IEEE Transactions on Power Systems*, 11(4), 1868-1873. <https://doi.org/10.1109/59.544656>
- Huang, Y.-C. (2002). Enhanced genetic algorithm-based fuzzy multi-objective approach to distribution network reconfiguration. *IEE Proceedings - Generation, Transmission and Distribution*, 149(5), 615-620. <https://doi.org/10.1049/ip-gtd:20020512>
- Su, C.-T., Chang, C.-F., & Chiou, J.-P. (2005). Distribution network reconfiguration for loss reduction by ant colony search algorithm. *Electric Power Systems Research*, 75(2-3), 190-199. <https://doi.org/10.1016/j.epsr.2005.03.002>
- Das, D. (2006). A fuzzy multiobjective approach for network reconfiguration of distribution systems. *IEEE Transactions on Power Delivery*, 21(1), 202-209. <https://doi.org/10.1109/TPWRD.2005.852335>
- Chang, C.-F. (2008). Reconfiguration and capacitor placement for loss reduction of distribution systems by ant colony search algorithm. *IEEE Transactions on Power Systems*, 23(4), 1747-1755. <https://doi.org/10.1109/TPWRS.2008.2002169>
- Eajal, A. A., & El-Hawary, M. E. (2010). Optimal capacitor placement and sizing in unbalanced distribution systems with harmonics consideration using particle swarm optimization. *IEEE Transactions on Power Delivery*, 25(3), 1734-1741. <https://doi.org/10.1109/TPWRD.2009.2035425>
- Srinivasa Rao, R., Narasimham, S. V. L., Ramalinga Raju, M., & Srinivasa Rao, A. (2011). Optimal network reconfiguration of large-scale distribution system using harmony search algorithm. *IEEE Transactions on Power Systems*, 26(3), 1080-1088. <https://doi.org/10.1109/TPWRS.2010.2076839>
- Sedighzadeh, M., Dakhem, M., Sarvi, M., & Hosseini Kordkheili, H. (2014). Optimal reconfiguration and capacitor placement for power loss reduction of distribution system using improved binary particle swarm optimization. *International Journal of Energy and Environmental Engineering*, 5, 73. <https://doi.org/10.1007/s40095-014-0073-9>
- Duan, D.-L., Ling, X.-D., Wu, X.-Y., & Zhong, B. (2015). Reconfiguration of distribution network for loss reduction and reliability improvement based on an enhanced genetic algorithm. *International Journal of Electrical Power & Energy Systems*, 64, 88-95. <https://doi.org/10.1016/j.ijepes.2014.07.036>
- Ali, E. S., Abd Elazim, S. M., & Abdelaziz, A. Y. (2016). Improved Harmony Algorithm for optimal locations and sizing of capacitors in radial distribution systems. *International Journal of Electrical Power & Energy Systems*, 79, 275-284. <https://doi.org/10.1016/j.ijepes.2016.01.015>
- Tamilselvan, V., Jayabarathi, T., Raghunathan, T., & Yang, X.-S. (2018). Optimal capacitor placement in radial distribution systems using flower pollination algorithm. *Alexandria Engineering Journal*, 57(4), 2775-2786. <https://doi.org/10.1016/j.aej.2018.01.004>