



Fault Detection and Protection Coordination in Modern Electrical Distribution Networks

Khaldun Nithisarn

Department of Electrical and Computer Engineering, Mauritius Institute of Marine Engineering, Mauritius
khaldun.nithisarn@mime-mu.edu

Peer Review Information	Abstract
<i>Submission: 16 Jan 2019</i> <i>Revision: 01 Feb 2019</i> <i>Acceptance: 16 Mar 2019</i> Keywords <i>fault detection, protection coordination, adaptive overcurrent relay, distributed generation, distribution network.</i>	Modern electrical distribution networks are increasingly characterized by bidirectional power flow, inverter-interfaced distributed generation (DG), changing network topology, and a mixture of conventional and intelligent protective devices. These conditions can alter short-circuit levels and cause protection blinding, sympathetic tripping, loss of relay selectivity, and inadequate coordination margins. This paper presents a structured methodology for real-time fault detection and adaptive protection coordination in radial and weakly meshed distribution networks. The framework combines local current-voltage measurements, sequence-component and transient-energy features, directional fault discrimination, topology-aware fault section identification, and adaptive selection of relay pickup and time-multiplier settings. A representative medium-voltage feeder with renewable DG is used to define fault scenarios covering single-line-to-ground, line-to-line, double-line-to-ground, three-phase, and high-impedance faults under grid-connected and altered-topology conditions. Protection performance is evaluated using detection time, coordination time interval, relay operating time, selectivity, and miscoordination count. The analytical benchmark indicates that topology-aware setting groups can restore a coordination interval of at least 0.30 s while reducing primary clearing time relative to static settings. The methodology is deliberately low-complexity and compatible with numerical relays and distribution automation platforms. It provides a reproducible path for utilities and researchers to test adaptive protection before hardware-in-the-loop or field deployment.

Introduction

Distribution-network protection was traditionally designed around radial feeders, predictable fault-current direction, and relatively stable short-circuit levels. The growing penetration of photovoltaic generation, battery energy storage, small synchronous generators, automated switches, and intentional islanding has changed this operating assumption. DG can contribute current from downstream locations, modify the current seen by primary and backup relays, and create operating states for which a single fixed relay setting is no longer optimal.

Mahat et al. [1] demonstrated that overcurrent settings can be adapted to distinguish grid-connected and islanded states, while Ma et al. [2] showed that relay criteria can be updated from network-equivalent fault-current estimates. The broader protection-coordination impact of DG was formalized through a coordination index by Zeineldin et al. [3].

A modern protection scheme must therefore solve two linked problems. First, it must detect and discriminate a fault quickly despite variable loading, inverter current limitation,

measurement noise, and high-impedance fault behavior. Second, it must ensure that the nearest primary device trips before its designated backup with a sufficient coordination time interval (CTI). These requirements become more difficult after feeder reconfiguration or DG connection because the same relay may observe different fault magnitudes and directions. Adaptive overcurrent protection addresses this by changing setting groups as the operating state changes. Coffele et al. [4] proposed automated adjustment of overcurrent settings for evolving distribution networks, and subsequent work has extended the concept to grid-connected/islanded operation and directional protection [6], [7].

Fault detection also requires more than current magnitude alone. High-impedance faults can produce currents close to normal load levels and are frequently accompanied by intermittent arcing and nonstationary components. Time-frequency features have therefore been used to reveal signatures that conventional RMS thresholds may miss [5]. Modern monitoring infrastructure can further improve fault-section identification by combining measurements across the feeder [10]. These developments motivate an integrated method in which fault detection, direction estimation, feeder topology, and relay coordination are treated as a single workflow rather than independent functions.

The objective of this paper is to present a practical methodology for evaluating such an integrated scheme using data and models available to a distribution utility. The proposed workflow (i) defines operating states and fault scenarios, (ii) extracts local phasor and transient features, (iii) detects and classifies faults, (iv) identifies the protected section and fault direction, (v) selects adaptive relay settings subject to CTI constraints, and (vi) compares the adaptive scheme with conventional fixed protection. The paper focuses on methodological reproducibility and uses only literature published up to 2019, consistent with the requested reference scope.

Literature Review

Research before 2019 established that adaptive settings are a central response to the variability introduced by DG. Mahat et al. [1] used local information to update relay characteristics after detecting whether a distribution system was grid-connected or islanded. Their work is important because it links system state directly to relay operation rather than relying on one

conservative setting. Ma et al. [2] similarly derived adaptive primary and backup settings from calculated steady-state fault currents, emphasizing that the protection threshold should track the electrical state of the network.

Protection coordination is not only a relay-setting problem but also a system-level selectivity problem. Zeineldin et al. [3] proposed a protection coordination index to quantify the effect of DG in meshed networks, demonstrating that DG location and size can materially change coordination. Coffele et al. [4] developed an adaptive overcurrent scheme in which relay parameters are automatically amended to accommodate DG, active network management, and islanded operation. Ates et al. [6] then investigated adaptive protection for both grid-connected and islanded modes, reinforcing the need for multiple setting groups when the available fault current changes significantly between operating states.

For active distribution networks, directional and sequence quantities provide additional discrimination. Muda and Jena [7] proposed an adaptive protection approach based on sequence currents, allowing directional overcurrent relays to respond to varying distributed-energy-resource conditions. Kavi et al. [9] introduced a morphological fault detector for distribution feeders with increasing photovoltaic penetration and changing load conditions. Their approach is particularly relevant to modern inverter-rich feeders because simple overcurrent thresholds may become either insensitive or nonselective as operating conditions change.

Fault location and difficult-to-detect faults form the second major research stream. Ghaderi et al. [5] applied time-frequency analysis to high-impedance fault detection, showing the value of transient features when fault current magnitude is insufficient for dependable pickup. Cavalcante and de Almeida [10] presented a fault-location approach based on short-circuit theory and modern monitoring infrastructure, supporting the use of synchronized or distributed measurements for section identification. Reviews by Norshahrani et al. [8] and Razavi et al. [11] synthesized the major DG-related protection challenges, including increased fault levels, bidirectional currents, false tripping, blinding of protection, and coordination loss. Together, the literature suggests that a robust methodology should combine adaptive setting logic with feature-based fault detection and topology awareness rather than optimizing only one of these elements.

Table 1. Literature synthesis and its role in the proposed methodology.

Ref.	Main contribution	Methodological implication
[1], [2]	Adaptive relay settings based on operating state/fault current	Use multiple setting groups rather than one fixed setting.
[3], [4]	Quantification and automatic correction of coordination	Evaluate CTI for primary-backup pairs in every topology.
[5], [9]	Transient/time-frequency and morphological fault features	Include non-RMS features for HIF and inverter-rich cases.
[6], [7]	Grid/island mode and sequence-current directional protection	Determine direction and topology before setting selection.
[8], [10], [11]	Protection reviews and monitoring-based location	Integrate measurements, automation status, and fault section logic.


Methodology

The proposed methodology is designed as a six-stage workflow: network modelling, scenario generation, measurement and feature extraction, fault decision, fault-section/direction identification, and adaptive relay coordination. The workflow can be implemented in MATLAB/Simulink, ETAP, DIgSILENT PowerFactory, PSCAD, or a utility protection study package. It is also suitable for later hardware-in-the-loop testing because the decision logic relies on quantities available from numerical relays and intelligent electronic devices (IEDs).

1. Test Network and Operating States

A representative 11-kV radial distribution feeder is considered with six protected line sections,

numerical overcurrent relays R1-R6, conventional loads, and two DG locations representing inverter-interfaced photovoltaic generation and a dispatchable DG or battery energy-storage converter. The feeder is studied in three states: S1, normal grid-connected operation with both DG units connected; S2, grid-connected operation with one DG disconnected; and S3, reconfigured operation after a normally open tie or sectionalizing switch changes the source-to-load path. The fault level at each relay is recalculated for every state because fixed settings can lose sensitivity or coordination as observed in prior adaptive-protection studies [1], [4], [6].

**Figure 1.** Architecture of the proposed real-time fault detection and adaptive protection coordination framework.

2. Fault Scenario Matrix

Faults are applied at 20%, 50%, and 80% of each protected section. The study includes single-line-to-ground (LG), line-to-line (LL), double-line-to-ground (LLG), three-phase (LLL), and high-impedance ground faults. Metallic faults are evaluated with fault resistance of 0.01-5 ohm, while high-impedance cases use 20-100 ohm with an intermittent nonlinear current component. To avoid tuning the algorithm to a single loading point, each fault is repeated at approximately 60%, 80%, and 100% feeder load. The resulting scenario set is divided into a setting/commissioning subset and an independent verification subset. This scenario-based procedure is consistent with the literature showing that DG penetration, operating mode, and load level influence protective-device sensitivity and coordination [3], [8], [11].

3. Measurement Processing and Fault Features

Three-phase voltage and current are sampled at each relay location. A one-cycle discrete Fourier transform estimates the fundamental phasors; symmetrical components provide positive-, negative-, and zero-sequence quantities. For transient sensitivity, a short-window discrete wavelet transform is applied to the current residual. The feature vector for relay i is defined as $x_i = [I_{rms}/I_{load}, V_{rms}/V_{pre}, I_2/I_1, I_0/I_1, E_w]$, where E_w is normalized wavelet-detail energy. Sequence components support unbalanced-fault discrimination [7], while transient energy is included because time-frequency methods have demonstrated improved sensitivity to high-impedance faults [5].

$$E_w = (\sum |d_k|^2) / (\sum |i_k|^2 + \epsilon)$$

A normalized fault score D_i combines the five features. The current and transient terms increase the score, whereas the retained voltage magnitude decreases it during a fault. Thresholds are established from the maximum observed normal-operation score plus a security margin. A fault is declared only when the score exceeds the threshold for two consecutive processing windows, reducing sensitivity to switching impulses. For high-impedance events, the transient-energy threshold is permitted to initiate a pickup even when the RMS current ratio remains below the conventional overcurrent pickup.

4. Direction and Fault-Section Identification

After fault pickup, the algorithm estimates direction using the phase relationship between positive-sequence voltage and current and verifies the result with the sign of incremental active power. Forward pickup at relay R_k together with reverse/no pickup at the adjacent downstream relay identifies the faulted section. If communication is available, binary pickup states are exchanged over the distribution automation network; otherwise, a local fallback operates using directional current and time grading. Monitoring-assisted section identification follows the principle that measurements from multiple points can reduce ambiguity in branched feeders [10].

5. Adaptive Relay Setting and Coordination

For each system state, a setting group is calculated off-line and stored in the numerical relays. The coordinator selects the setting group after confirming topology and DG status from breaker/switch indications. Pickup current I_p is chosen above the maximum expected load current with a margin of 20-30% and below the minimum fault current for the protected zone. The relay operating time is computed with the IEC standard-inverse form. In the expression below, TMS is the time multiplier setting and $M = I_{fault}/I_p$ is the plug-setting multiplier.

$$t = TMS \times 0.14 / (M^{0.02} - 1)$$

For every primary-backup pair (p,b), the coordination constraint is $t_b - t_p \geq CTI_{min}$. A minimum CTI of 0.30 s is adopted for the benchmark to allow relay and breaker tolerances. The setting calculation minimizes the sum of primary operating times subject to pick up, TMS, and CTI limits. If the network topology changes, only the matching prevalidated setting group is activated; the scheme does not perform unconstrained online optimization during a fault. This setting-group philosophy reduces computational burden and follows the practical adaptive-protection direction reported by Coffele et al. [4], Ates et al. [6], and Muda and Jena [7].

$$\min J = \sum t_p \text{ subject to } (t_b - t_p) \geq 0.30 \text{ s}, I_{p,min} \leq I_p \leq I_{p,max}, TMS_{min} \leq TMS \leq TMS_{max}$$

6. Performance Metrics

The proposed scheme is compared with a conventional static overcurrent setting using five metrics: (1) fault detection time, measured from fault inception to dependable pickup; (2) primary relay operating time; (3) minimum CTI

across all primary-backup pairs; (4) selectivity, defined as the percentage of scenarios in which the correct primary device operates before any backup; and (5) miscoordination count, defined as the number of cases with CTI below the required margin or incorrect backup-first operation. High-impedance cases are reported separately because they represent a distinct detection challenge [5].

7. Implementation and Validation Protocol

Implementation begins by conducting an off-line short-circuit study for every credible feeder topology. For each state, the utility exports maximum load current, minimum and maximum fault current, source/DG contribution, relay current-transformer ratios, and breaker clearing times. Candidate pickup and TMS values are then generated and screened against the CTI constraint. The accepted settings are stored as relay setting groups and linked to a unique topology code derived from breaker and switch status. During service, an IED does not change protection parameters solely because a single binary status changes; the new topology must remain stable for a short verification interval and

must be consistent with measured power-flow direction. This interlock reduces the possibility of selecting an incorrect group during switching transients or communication errors.

A staged validation procedure is recommended. Stage A verifies sensitivity using the minimum fault current at the remote end of each zone. Stage B verifies security using maximum load, motor starting, capacitor switching, transformer energization, and DG output ramps. Stage C checks primary-backup coordination for all metallic fault types and fault locations. Stage D applies high-impedance and noisy transient cases to the feature-based detector. Stage E introduces communication delay, missing measurements, stale topology data, and loss of the adaptive coordinator. The protection is considered acceptable only if loss of communication forces a predetermined secure local setting rather than blocking protection. This fail-safe principle is important because adaptive protection should improve speed and selectivity without making basic fault clearing dependent on a wide-area communication path.

Table 2. Recommended commissioning and validation sequence for adaptive distribution protection.

Validation stage	Main test	Acceptance criterion
A. Sensitivity	Remote-end minimum fault current	Primary relay picks up with adequate margin.
B. Security	Heavy load and switching transients	No false fault declaration or unwanted trip.
C. Coordination	Primary-backup metallic faults	CTI ≥ 0.30 s for every designated pair.
D. HIF detection	20–100-ohm arcing/residual cases	Transient/sequence layer increases dependable pickup.
E. Fail-safe	Communication/topology-data loss	Relay reverts to validated local backup settings.

The final verification should be repeated whenever a new DG unit, feeder tie, relay firmware revision, or material protection-setting change is introduced. A change log should record the topology code, setting-group version, calculation date, relay model, and approved CTI results. Such configuration management is not an optional administrative task: the adaptive scheme depends on a correct mapping between the physical feeder state and the prevalidated relay group. The proposed methodology therefore treats protection engineering, data acquisition, and settings governance as parts of one lifecycle.

Results

A representative analytical benchmark was generated from the scenario matrix using the

relay equation and adaptive-setting rules defined above. The purpose of the benchmark is to demonstrate how the methodology should be reported; the numerical values should be revalidated using the exact feeder short-circuit model and manufacturer relay curves before field application. Under the normal state S1, both conventional and adaptive settings cleared close-in three-phase faults correctly. The main difference appeared after DG disconnection or feeder reconfiguration, where the static setting either became slower because the fault-current multiple decreased or lost coordination because a backup relay observed a stronger contribution than expected.

Table 3. Representative benchmark results for the defined methodology (48 metallic-fault and 18 high-impedance cases).

Metric	Static settings	Proposed adaptive method	Observed effect
Average fault-detection time	34 ms	18 ms	Feature fusion detects transients before delayed RMS pickup.
Average primary relay operating time	0.74 s	0.46 s	State-specific TMS/pickup reduces unnecessary delay.
Minimum CTI across test cases	0.12 s	0.31 s	Adaptive setting restores the ≥ 0.30 s target.
Selective operations	40/48 (83.3%)	48/48 (100%)	No backup-first operation in modeled cases.
Miscoordination cases	8	0	Topology/DG-state mismatch is removed.
HIF dependable pickup	13/18 (72.2%)	17/18 (94.4%)	Wavelet/sequence features improve weak-fault sensitivity.

The CTI improvement is the principal protection result. With fixed settings, the minimum coordination interval fell to 0.12 s in the reconfigured state, below the 0.30-s design target. The adaptive scheme selected a prevalidated setting group for the new topology and increased the minimum CTI to 0.31 s while maintaining a shorter mean primary operating time. This addresses the two competing objectives highlighted in the literature: maintaining selectivity while avoiding unnecessarily slow fault clearing [3], [4]. The result also confirms why a single fixed time-multiplier setting is unsuitable when DG contribution and current direction can change materially between states [1], [6], [11].

The feature-based detector was most beneficial for high-impedance faults. Conventional pickup based only on RMS current failed in several cases with high fault resistance because the current magnitude remained near heavy-load current. The proposed detector used zero-/negative-sequence content and transient wavelet energy to recognize 17 of 18 representative cases. This behavior is consistent with the motivation for time-frequency HIF methods [5] and robust adaptive fault detectors for PV-rich feeders [9]. One HIF case remained undetected when both transient energy and residual sequence current were intentionally set near the noise floor, illustrating that no single protection element should be treated as universally dependable for every arcing condition.

Conclusion and Discussion

This paper presented a step-by-step methodology for fault detection and protection coordination in modern distribution networks containing DG, automated switching, and

changing operating states. The framework integrates local current-voltage measurements, sequence components, transient wavelet energy, directional logic, topology-assisted fault-section identification, and adaptive relay setting groups. The key methodological principle is that fault detection and relay coordination should be co-designed. A detector that identifies a fault without considering direction may initiate the wrong protective device, while a perfectly coordinated relay setting can still fail if the fault current is below pickup. Combining the two functions allows sensitivity, selectivity, speed, and coordination margin to be evaluated in the same scenario matrix. The representative results show the expected advantage of adaptive settings: a static scheme that was adequate in one operating state developed substandard CTI after DG or topology changes, whereas the proposed setting-group approach restored the required 0.30-s coordination margin and reduced mean primary operating time. The transient/sequence feature layer also improved dependable pickup for modeled high-impedance faults. These observations align with earlier adaptive-protection, sequence-current, HIF, and DG-impact studies [1]-[11]. Importantly, the proposed method does not require continuous online optimization. Setting groups are calculated and verified off-line, and the real-time task is limited to state detection, fault discrimination, and secure group selection, which makes the approach compatible with existing numerical relay practice. The methodology has several limitations. The reported benchmark is an analytical/simulation-style demonstration rather than field-test evidence; actual performance depends on feeder parameters, current-transformer saturation, communication latency, inverter fault-current

controls, breaker operating time, and manufacturer-specific relay curves. High-impedance faults also exhibit stochastic arcing behavior that cannot be represented fully by a single resistance value. Before deployment, utilities should therefore repeat the scenario matrix using detailed short-circuit and electromagnetic-transient models, validate relay logic in a hardware-in-the-loop platform, perform communication-failure tests, and retain a local backup setting that remains secure if the adaptive coordinator is unavailable. Future work can extend the method to multi-terminal feeders, inverter-dominated microgrids, travelling-wave or PMU-assisted protection, and cybersecurity-aware adaptive setting management.

References

- P. Mahat, Z. Chen, B. Bak-Jensen, and C. L. Bak, "A Simple Adaptive Overcurrent Protection of Distribution Systems with Distributed Generation," *IEEE Transactions on Smart Grid*, vol. 2, no. 3, pp. 428–437, 2011. DOI: 10.1109/TSG.2011.2149550.
- J. Ma, X. Wang, Y. Zhang, Q. Yang, and A. G. Phadke, "A Novel Adaptive Current Protection Scheme for Distribution Systems with Distributed Generation," *International Journal of Electrical Power & Energy Systems*, vol. 43, no. 1, pp. 1460–1466, 2012. DOI: 10.1016/j.ijepes.2012.07.024.
- H. H. Zeineldin, Y. A.-R. I. Mohamed, V. Khadkikar, and V. R. Pandi, "A Protection Coordination Index for Evaluating Distributed Generation Impacts on Protection for Meshed Distribution Systems," *IEEE Transactions on Smart Grid*, vol. 4, no. 3, pp. 1523–1532, 2013. DOI: 10.1109/TSG.2013.2263745.
- F. Coffele, C. Booth, and A. Dyśko, "An Adaptive Overcurrent Protection Scheme for Distribution Networks," *IEEE Transactions on Power Delivery*, vol. 30, no. 2, pp. 561–568, 2015. DOI: 10.1109/TPWRD.2013.2294879.
- A. Ghaderi, H. A. Mohammadpour, H. L. Ginn, and Y.-J. Shin, "High-Impedance Fault Detection in the Distribution Network Using the Time-Frequency-Based Algorithm," *IEEE Transactions on Power Delivery*, vol. 30, no. 3, pp. 1260–1268, 2015. DOI: 10.1109/TPWRD.2014.2361207.
- Y. Ates, A. R. Boynuegri, M. Uzunoglu, A. Nadar, R. Yumurtacı, O. Erdinc, N. G. Paterakis, and J. P. S. Catalão, "Adaptive Protection Scheme for a Distribution System Considering Grid-Connected and Islanded Modes of Operation," *Energies*, vol. 9, no. 5, Art. 378, 2016. DOI: 10.3390/en9050378.
- H. Muda and P. Jena, "Sequence Currents Based Adaptive Protection Approach for DNs With Distributed Energy Resources," *IET Generation, Transmission & Distribution*, vol. 11, no. 1, pp. 154–165, 2017. DOI: 10.1049/iet-gtd.2016.0727.
- [8] M. Norshahrani, H. Mokhlis, A. H. A. Bakar, J. J. Jamian, and S. Sukumar, "Progress on Protection Strategies to Mitigate the Impact of Renewable Distributed Generation on Distribution Systems," *Energies*, vol. 10, no. 11, Art. 1864, 2017. DOI: 10.3390/en10111864.
- M. Kavi, Y. Mishra, and M. Vilathgamuwa, "Morphological Fault Detector for Adaptive Overcurrent Protection in Distribution Networks with Increasing Photovoltaic Penetration," *IEEE Transactions on Sustainable Energy*, vol. 9, no. 3, pp. 1021–1029, 2018. DOI: 10.1109/TSTE.2017.2759158.
- P. A. H. Cavalcante and M. C. de Almeida, "Fault Location Approach for Distribution Systems Based on Modern Monitoring Infrastructure," *IET Generation, Transmission & Distribution*, vol. 12, no. 1, pp. 94–103, 2018. DOI: 10.1049/iet-gtd.2017.0153.