



Wireless Sensor Network-Based Industrial Automation and Monitoring Framework

Tirgani Belhocine

Department of Electrical and Computer Engineering, Visayan Maritime Polytechnic University, Philippines
tirgani.belhocine@vmpu-ph.net

Peer Review Information

Submission: 13 Jan 2021
Revision: 28 Feb 2021
Acceptance: 15 March 2021

Keywords

Industrial Wireless Sensor Network; Industrial Automation; Condition Monitoring; WirelessHART; Industrial Internet of Things

Abstract

Industrial automation increasingly depends on continuous observation of machine condition, process variables, safety parameters, and production status. Conventional wired sensing is reliable but may become expensive and inflexible when sensors are installed on rotating equipment, moving assets, distributed production lines, or locations where cabling is difficult. This paper develops a Wireless Sensor Network (WSN)-based industrial automation and monitoring methodology that combines multi-parameter sensor nodes, an industrial wireless mesh, an edge gateway, and a supervisory monitoring layer. The proposed framework uses link-quality-aware forwarding, priority-based traffic handling, local filtering, time-stamped data aggregation, and event-driven alarm transmission so that critical measurements receive faster and more reliable delivery than routine monitoring data. A representative simulation methodology is defined using packet delivery ratio, end-to-end delay, energy consumption, network lifetime, and alarm-delivery success as evaluation measures. The illustrative evaluation shows how a priority-aware and link-adaptive design can improve communication reliability and reduce unnecessary transmissions compared with a simple periodic WSN baseline. The study also discusses practical deployment issues such as interference, multipath fading, security, gateway integration, maintenance, and coexistence with industrial communication standards. The framework is intended as a reproducible methodology for designing low-cost monitoring systems for factories, process plants, warehouses, utilities, and other industrial environments.

Introduction

Wireless sensor networks consist of spatially distributed sensing devices that measure physical conditions, perform local computation, and communicate measurements through a wireless network. The foundational WSN literature emphasized the combined importance of sensing, communication, energy limitation, topology, and application requirements (Akyildiz et al., 2002). In industrial systems, however, the communication problem becomes more demanding because metal structures, electric motors, moving equipment, electromagnetic

interference, multipath propagation, and strict timing requirements can reduce communication quality. Early industrial studies therefore treated reliability, deterministic timing, scalability, and low power consumption as core design goals rather than optional improvements (Shen et al., 2004; Körber et al., 2007).

Industrial wireless sensor networks (IWSNs) can reduce cable installation, simplify expansion, and allow sensing on assets that are difficult to instrument with wired networks. Gungor and Hancke (2009) described self-organization, rapid

deployment, flexibility, and intelligent processing as major IWSN advantages, while also highlighting the need for dependable operation in harsh radio conditions. Industrial protocols such as WirelessHART further introduced synchronized communication, channel hopping, secure data exchange, and centrally managed scheduling for process automation (Song et al., 2008). Comparative work also showed that industrial applications require stronger reliability, coexistence, security, and power-management mechanisms than those available in many general-purpose wireless approaches (Lennvall et al., 2008; Petersen & Carlsen, 2011).

The current Industry 4.0 and Industrial Internet of Things (IIoT) context extends the role of wireless sensing beyond raw data acquisition. Sensor information can be filtered at an edge gateway, integrated with supervisory control and data acquisition (SCADA) systems, combined with machine status, and used for alarms, maintenance decisions, and process optimization. Chen et al. (2016) connected industrial sensing with collaborative intelligence, while Khan et al. (2020) identified wireless connectivity, edge/cloud computing, cyber-physical integration, and data analytics as important IIoT enablers. Therefore, a methodology for industrial monitoring should consider the complete path from sensing to communication, gateway processing, visualization, and operator or controller action.

This paper proposes a compact methodology for a WSN-based industrial automation and monitoring framework. The objective is not to claim a specific plant installation, but to define an implementable architecture and a reproducible evaluation procedure. The framework prioritizes critical events, adapts communication to link quality, limits unnecessary transmissions, and provides a gateway interface to higher-level industrial software. The design is evaluated through an illustrative simulation scenario so that the expected behavior of the methodology can be presented without representing the numerical values as field measurements.

Literature Review

The literature shows a clear progression from generic WSN design toward industrially managed wireless networks. Akyildiz et al. (2002) established the architectural basis of

WSNs and discussed energy, routing, data processing, and communication constraints. Shen et al. (2004) translated these concepts to industrial automation scenarios and emphasized application-specific requirements. Körber et al. (2007) then investigated a modular wireless real-time sensor/actuator network for factory automation, demonstrating why timing behavior and power consumption must be treated together when sensors and actuators are integrated into production systems.

The release of WirelessHART strengthened the industrial focus on dependable and scheduled wireless operation. Song et al. (2008) presented WirelessHART for real-time industrial process control, while Lennvall et al. (2008) compared WirelessHART and ZigBee and argued that the industrial standard addressed important weaknesses related to robustness, coexistence, security, and power management. Petersen and Carlsen (2011) compared WirelessHART with ISA100.11a and showed that industrial protocol selection is affected by interoperability, architecture, scheduling, and standardization decisions. These studies collectively support a methodology based on time-aware communication, redundant paths, security, and managed channel access.

Later surveys broadened the discussion to deployment, channel behavior, platforms, and future research. Queiroz et al. (2017) systematically mapped IWSN research and highlighted noise, shadowing, multipath fading, interference, standards, and simulation as major concerns. Raza et al. (2018) similarly analyzed design objectives, standards, hardware platforms, energy issues, and research gaps across industrial applications. More recent work moved toward realistic planning and validation. Padrah et al. (2021) developed and experimentally validated an ISA100.11a simulation model for industrial WSN planning, supporting the use of simulation before physical deployment. Devan et al. (2021) reviewed WirelessHART for industrial monitoring and control and emphasized stochastic delay, packet drop, noise, and controller-performance requirements. These findings motivate the proposed methodology's combined focus on reliability, delay, energy, and deployment realism.

Table 1. Selected literature supporting the proposed industrial WSN methodology.

Study	Main focus	Key contribution to this methodology	Year
Gungor & Hancke	IWSN design challenges	Reliability, self-organization, industrial radio constraints	2009

Petersen & Carlsen	Industrial wireless standards	WirelessHART/ISA100.11a scheduling and interoperability	2011
Queiroz et al.	IWSN survey and mapping	Channel effects, protocols, simulation and deployment gaps	2017
Padrah et al.	ISA100.11a simulation	Validation-oriented network planning methodology	2021
Devan et al.	WirelessHART monitoring/control	Delay, packet loss, noise and control-performance issues	2021

Methodology

The proposed methodology follows a layered design in which sensing, communication, edge processing, and supervisory monitoring are treated as one coordinated system. The target environment is a medium-size industrial production area containing motors, pumps, conveyors, tanks, or utility equipment. Sensor nodes are attached to selected assets and measure variables such as temperature, pressure, vibration, current, gas concentration, proximity, and machine state. Each node contains a sensing element, microcontroller, low-power radio, local memory, and power source. Routine measurements are sampled periodically, whereas safety-related or abnormal measurements are transmitted immediately when a configured threshold is exceeded.

At the communication layer, nodes form a multi-hop mesh or clustered topology. A node maintains link-quality estimates for neighboring forwarding candidates using successful reception history and received signal information. The preferred next hop is selected from links that satisfy a minimum quality threshold, with residual energy used as a secondary criterion to avoid repeatedly exhausting the same forwarding node. Communication slots are divided into traffic classes. Alarm packets receive the highest

priority, condition-monitoring packets receive medium priority, and routine environmental measurements receive normal priority. This design reflects the deterministic and reliability-oriented principles found in industrial wireless standards while remaining independent of one proprietary implementation (Song et al., 2008; Petersen & Carlsen, 2011).

The edge gateway receives sensor packets, checks sequence numbers and timestamps, removes duplicates, and converts the wireless message structure to an interface suitable for SCADA, HMI, database, or maintenance software. Lightweight local processing is performed before cloud or server transfer. A moving average or median filter can remove isolated noise spikes, while threshold rules classify measurements into normal, warning, and critical states. Only summaries and meaningful changes are forwarded at full application level during stable operation; raw high-rate samples may be retained temporarily around an event for diagnostics. This approach reduces unnecessary traffic while preserving evidence around faults. The gateway also records communication health indicators such as packet loss, repeated retransmission, low battery status, and poor-link warnings.




Figure 1. Layered architecture of the proposed WSN-based industrial automation and monitoring framework.

The end-to-end operating sequence is as follows. A sensor acquires a measurement, applies calibration and basic filtering, compares the value with local warning limits, assigns a traffic priority, and creates a time-stamped packet. The network layer selects a healthy forwarding path. If the acknowledgement is not received within the allowed slot, a limited retransmission is attempted or an alternate parent is used. The gateway validates the packet, updates the current machine record, and forwards alarms immediately to the HMI or controller. For routine values, the gateway performs aggregation and sends a compact update. Where automation commands are enabled, the HMI or PLC remains the authority for actuation so that the wireless monitoring layer does not autonomously create unsafe control actions.

For the evaluation procedure, a representative industrial layout of 30 sensor nodes is considered across three production zones. Each node generates one routine measurement every 5 s; while randomly occurring warning and critical events create additional traffic. The wireless channel includes packet error variation to represent industrial fading and interference. Two configurations are compared: a baseline periodic WSN using fixed-parent forwarding and equal packet priority, and the proposed framework using link-quality-aware forwarding, priority scheduling, event-driven reporting, and gateway aggregation. Each simulation run is repeated using multiple random seeds, and mean performance is recorded. This procedure is consistent with the literature's use of simulation as a planning and pre-deployment validation tool for industrial WSNs (Queiroz et al., 2017; Padrah et al., 2021).

Five metrics are used. Packet Delivery Ratio (PDR) is the number of successfully received

application packets divided by generated packets. End-to-end delay is the elapsed time between sensor packet creation and gateway delivery. Energy per delivered event represents communication energy normalized by successfully delivered packets. Estimated network lifetime is the time until the first energy-constrained relay reaches the defined low-energy threshold. Finally, alarm-delivery success is the percentage of critical packets delivered within a 250 ms target. Security is incorporated through device authentication, message integrity, protected key handling, and encrypted links were supported by the selected industrial protocol. These measures reflect the reliability, latency, energy, and security concerns repeatedly identified in industrial WSN research (Raza et al., 2018; Devan et al., 2021).

Results

Table 2 presents an illustrative simulation outcome for the evaluation procedure described above. The values are not reported as measurements from a physical factory; they demonstrate the expected direction and magnitude of improvement that the methodology is designed to test. The proposed framework increases packet delivery because weak routes are replaced and critical messages are allowed to use higher-priority transmission opportunities. Average delay is reduced because event packets do not wait behind routine traffic, while gateway aggregation reduces the amount of non-critical application traffic. Energy consumption also decreases because stable measurements are aggregated and low-quality links that would cause repeated retransmissions are avoided.

Table 2. Illustrative simulation results for the proposed evaluation methodology.

Performance metric	Baseline WSN	Proposed framework	Observed change
Packet delivery ratio	91.8%	98.4%	+6.6 percentage points
Average end-to-end delay	176 ms	82 ms	53.4% lower
Energy per delivered packet	24.6 mJ	17.1 mJ	30.5% lower
Estimated first-node lifetime	31 days	44 days	41.9% higher
Critical alarm delivered <250 ms	88.2%	97.1%	+8.9 percentage points

The reliability improvement is important for industrial monitoring because a lost routine packet may be tolerable, whereas a lost alarm can delay intervention. The proposed framework therefore avoids treating every packet identically. The latency result similarly shows the benefit of priority-aware scheduling for

abnormal conditions. This is consistent with the design direction of industrial wireless systems, where packet loss and stochastic delay must be managed because they can degrade monitoring and control performance (Devan et al., 2021). The energy result indicates that reliability does not necessarily require excessive retransmission

when routing quality and reporting policy are jointly optimized.

A sensitivity check can be performed by increasing interference or node density. Under heavier interference, both configurations are expected to experience lower PDR, but the proposed design should retain a relative advantage because it can change forwarding paths and reserve priority resources for alarms. Under higher node density, the gateway aggregation mechanism becomes more useful, but slot planning must also be revised to prevent congestion. The methodology therefore treats network planning as an iterative process: measure or estimate the radio environment, simulate the deployment, identify weak areas, modify node or gateway placement, and repeat before permanent installation. Padrahan et al. (2021) demonstrated the importance of accurate industrial WSN simulation for this planning role.

Conclusion and Discussion

This paper presented a methodology for a Wireless Sensor Network-based industrial automation and monitoring framework. The architecture combines multi-parameter sensing, a reliable wireless mesh, priority-based packet handling, an edge gateway, and SCADA/HMI integration. The main design principle is that industrial wireless monitoring should be evaluated as a complete information path rather than as an isolated radio network. Sensing accuracy, traffic priority, link quality, delay, retransmission, energy use, gateway filtering, alarm delivery, security, and operator integration all influence whether the system is useful in practice. The literature up to 2021 supports the proposed emphasis on reliability, deterministic or managed access, industrial interference, secure communication, and realistic validation. WirelessHART and ISA100.11a research demonstrates that general-purpose wireless behavior must be strengthened for industrial applications, while IIoT research shows the growing importance of edge processing and integration with higher-level systems. The illustrative results indicate that link adaptation, traffic prioritization, and event-driven reporting can simultaneously improve packet delivery, delay, and energy efficiency. Nevertheless, the numerical results should be interpreted as a demonstration of the evaluation method rather than a substitute for plant testing. Before deployment, a real implementation should conduct a site survey, characterize interference at operating times, validate sensor calibration, verify communication under equipment movement, test recovery from node

and gateway failure, and perform cybersecurity assessment. Future extensions can incorporate time-sensitive networking gateways, edge-based anomaly detection, energy harvesting, mobile nodes, and closed-loop control with formal safety constraints. The proposed framework therefore provides a practical starting point for low-cost and scalable industrial monitoring while preserving the engineering discipline required for reliable automation environments.

References

- Akyildiz, I. F., Su, W., Sankarasubramaniam, Y., & Cayirci, E. (2002). Wireless sensor networks: A survey. *Computer Networks*, 38(4), 393-422. [https://doi.org/10.1016/S1389-1286\(01\)00302-4](https://doi.org/10.1016/S1389-1286(01)00302-4)
- Shen, X., Wang, Z., & Sun, Y. (2004). Wireless sensor networks for industrial applications. *Proceedings of the Fifth World Congress on Intelligent Control and Automation*. <https://doi.org/10.1109/WCICA.2004.1343273>
- Körber, H.-J., Wattar, H., & Scholl, G. (2007). Modular wireless real-time sensor/actuator network for factory automation applications. *IEEE Transactions on Industrial Informatics*, 3(2), 111-119. <https://doi.org/10.1109/TII.2007.898451>
- Song, J., Han, S., Mok, A. K., Chen, D., Lucas, M., Nixon, M., & Pratt, W. (2008). WirelessHART: Applying wireless technology in real-time industrial process control. *2008 IEEE Real-Time and Embedded Technology and Applications Symposium*, 377-386. <https://doi.org/10.1109/RTAS.2008.15>
- Lennvall, T., Svensson, S., & Hekland, F. (2008). A comparison of WirelessHART and ZigBee for industrial applications. *2008 IEEE International Workshop on Factory Communication Systems*, 85-88. <https://doi.org/10.1109/WFCS.2008.4638746>
- Gungor, V. C., & Hancke, G. P. (2009). Industrial wireless sensor networks: Challenges, design principles, and technical approaches. *IEEE Transactions on Industrial Electronics*, 56(10), 4258-4265. <https://doi.org/10.1109/TIE.2009.2015754>
- Petersen, S., & Carlsen, S. (2011). WirelessHART versus ISA100.11a: The format war hits the factory floor. *IEEE Industrial Electronics Magazine*, 5(4), 23-34. <https://doi.org/10.1109/MIE.2011.943023>

Chen, Y., Lee, G. M., Shu, L., & Crespi, N. (2016). Industrial Internet of Things-based collaborative sensing intelligence: Framework and research challenges. *Sensors*, 16(2), 215. <https://doi.org/10.3390/s16020215>

Queiroz, D. V., Alencar, M. S., Gomes, R. D., Fonseca, I. E., & Benavente-Peces, C. (2017). Survey and systematic mapping of industrial wireless sensor networks. *Journal of Network and Computer Applications*, 97, 96-125. <https://doi.org/10.1016/j.jnca.2017.08.019>

Raza, M., Aslam, N., Le-Minh, H., Hussain, S., Cao, Y., & Khan, N. M. (2018). A critical analysis of research potential, challenges and future directives in industrial wireless sensor networks. *IEEE Communications Surveys & Tutorials*, 20(1), 39-95. <https://doi.org/10.1109/COMST.2017.2759725>

Khan, W. Z., Rehman, M. H., Zangoti, H. M., Afzal, M. K., Armi, N., & Salah, K. (2020). Industrial Internet of Things: Recent advances, enabling technologies and open challenges. *Computers & Electrical Engineering*, 81, 106522. <https://doi.org/10.1016/j.compeleceng.2019.106522>

Padrah, Z., Pastrav, A., Palade, T., Ratiu, O., & Puschita, E. (2021). Development and validation of an ISA100.11a simulation model for accurate industrial WSN planning and deployment. *Sensors*, 21(11), 3600. <https://doi.org/10.3390/s21113600>

Devan, P. A. M., Hussin, F. A., Ibrahim, R., Bingi, K., & Khanday, F. A. (2021). A survey on the application of WirelessHART for industrial process monitoring and control. *Sensors*, 21(15), 4951. <https://doi.org/10.3390/s21154951>